

Room & Spaces	No.	Light Switching				Mechanical, AC, Mech. Vent, Exhaust,							Comments
		BIMS oper. 7am 7pm	Individual Switch	Mot. sens. Delay min	Daylight sens	Ventilation	Air Conditioning	BIMS oper. 8am 6pm	Exhaust	Mot. sens. Delay min	Mech. Supply	Operation	
Covered Entry 1		AH											After Hours security lighting
Entries & lobbies		√/ AH					√	√			√	AC on scheduled Hours	After Hours security lighting
Corridor		√ /AH			√		√	√			√	As adjacent spaces	After Hours security lighting
Staff Spaces													
Workspaces, enclosed or open			√	√ 40	√		√	√		√ 40	√	AC Hours Ac switched	AC. After Hours Button
Meeting Rooms			√	√ 40	√		√	√		√ 40	√	AC Hours Ac switched	AC. After Hours Button
Copy/Print/Resource Room				√ 20	√		√	√	√	√ 40	√	AC on scheduled Hours Local exhaust on switch & delay	
Comms Room				√ 20			√	24/7	√			AC on 24hrs 7 days, with wider	
First Aid			√	√ 40	√		√	√		√ 40	√	AC Hours Ac switched	AC. After Hours Button
Toilets				√ 5	√				√	√ 5(w)		Exhaust on scheduled Hours (summer) Exhaust on movement (winter)	
Cleaners Room				√ 5					√	√ 60		Exhaust on scheduled Hours	
Store				√ 5					√	√ 60		Exhaust on scheduled Hours	Exhaust if required due to stored items
Tea Point		√			√		√	√			√	As adjacent spaces	
Tea Room /Lunchroom			√	√ 20	√		√	√	√	√(30)	√	AC on scheduled Hours Local exhaust on switch & delay	
Seminar / Tutorial Spaces		√	√		√		√	√			√	Lighting override switch AC on scheduled Hours	
Teaching Spaces Generally		√	√		√		√	√			√	Lighting override switch AC on scheduled Hours	

